



Integrating heat pumps in heat networks - 60/30



Energy trilemma



Design choices – 150 apartments

HP only

100% share




HP + CHP + boiler

45% + 40% + 15%



HEAT PUMP transfers heat





COLD



Heat Pump
300%!!!



WARM

Temperature
difference is a
must for heat
transfer




AIR

7°C outdoor
temperature

Heat transfer

High
temperature
(warmer)




Low
temperature
(cooler)

How do we move heat from a cooler area to a warmer area?


REFRIGERANT transfers heat

Example:
refrigerant R407C
approximate temperatures
Boiling point -44°C at atmospheric pressure




Compressor - pressurizes and circulates refrigerant

- compressor increases the pressure of a gas
- compressor is similar to pump:
 - ✓ increase the pressure on a fluid
 - ✓ can transport the fluid through a pipe




Heat pump relies on refrigerant pressure / temperature relationship

- temperature and pressure of a gas are proportionally related at a constant volume
- pressure is increased – temperature rises




REFRIGERANT transfers heat

Example:
refrigerant R407C
approximate temperatures





REFRIGERANT transfers heat

Example:
refrigerant R407C
approximate temperatures



During evaporation
heat is absorbed




During condensation
heat is released



EVAPORATION


CONDENSATION




Airflow: 22,000 m³/h

Evaporator

Fined tube coil
heat exchanger




Fan




$$\text{COP} = \frac{\text{energy out}}{\text{energy in}}$$

$$\text{COP} = \frac{3}{1} = 3.0$$




COP – outdoor temperature




Outdoor temp.	COP	HP operating temp.
10°C	4.58	30/35°C
5°C	3.63	30/35°C
0°C	2.90	30/35°C

COP – operating temperatures



Outdoor temp.	COP	HP operating temp.
5°C	3.63	30/35°C
5°C	3.06	40/45°C
5°C	2.49	50/55°C

COP – temperature gap to bridge



COP decreases with increasing temperature difference

Monetising return temperatures

43 kW HP

Outdoor temp.	HP operating temp.	COP	Power input	Energy cost		Emissions	
				£/h	£/year	kg CO ₂ /h	kg CO ₂ /year
5°C	30/35°C	3.63	12 kW	1.6	6,400	6.2	24,800
5°C	40/45°C	3.06	14.2 kW	1.9	7,600	7.4	29,600
5°C	50/55°C	2.49	17.5 kW	2.3	9,200	9.1	36,400

- Electricity price 13.19p/kWh
- Electricity CO₂ 0.519kg/kWh
- 4,000 operating hours per year



COP – snapshot efficiency

SCOP – seasonal COP

SCOP

- HP's average annual efficiency performance
- **should be used in project assessment**
- datasheet SCOP is based on 4,910 heating hours in Strasbourg
- ideally weather data from a project location should be used

SCOP – seasonal COP




- seasonal temperatures and demand weighted
- should be **at least 2.8**

Sizing – loads & diversity

150 two bedroom apartments	60/30
DHW load	35 kW
Heating load	2 kW
DHW diversity factor	0.0756
Heating diversity factor	0.6225
Peak plant without buffer	584 kW
Peak plant with buffer	256 kW
DHW buffer volume	2,000 l
DHW peak flow rate	2.2 l/s
Heating peak flow rate	1.6 l/s
Total peak flow rate	3.8 l/s
Plantroom pipe size	65 mm


Design temperatures		DHW	Heating
Heat Network (Primary)	Supply	60°C	60°C
	Return	17°C	32°C
Apartment (Secondary)	Supply	45°C	50°C
	Return	10°C	30°C

Heat Network - Fishbone Diagram




Heat pump buffer and COP

150 two bedroom apartments	60/30
DHW peak flow rate	2.2 l/s
Heating peak flow rate	1.6 l/s
Total peak flow rate	3.8 l/s




Heat pumps only design



- must achieve system flow temperature
- poor COP (heat pump operating 55/60°C)
- SCOP below 2.8

Outdoor temp.	COP	HP operating temp.
5°C	2.29	55/60°C

Heat pumps only design




- must achieve system flow temperature
- poor COP (heat pump operating 50/55°C)
- SCOP below 2.8


Outdoor temp.	COP	HP operating temp.
5°C	2.49	50/55°C

Heat pump as preheat - buffer and COP^{SAV}


150 two bedroom apartments	60/30
DHW peak flow rate	2.2 l/s
Heating peak flow rate	1.6 l/s
Total peak flow rate	3.8 l/s




Heat pump as preheat - buffer and COP^{SAV_s}



Heat pump as preheat - buffer and COP^{SAV_s}



Heat pump as preheat - buffer and COP^{SAV_s}



Plant selection (150 flats) - cost SAV_s

HP only plant room

Type of plant	Max. thermal output	Thermal store/buffer	Capital cost	Cost per flat
Heat pumps (CAHV)	6 x 43 kW	2,200 l	£22,700 each	
Total	258 kW	2,200 l	£136,000	£907

Hybrid plant room

Type of plant	Max. thermal output	Thermal store/buffer	Capital cost	Cost per flat
CHP (XRGI 20)	39 kW	500 l	£42,000	
Heat pump (CAHV)	43 kW	500 l	£23,000	
Boiler (gas or electric)	174 kW	2,000 l	£16,000	
Total	256 kW	3,000 l	£81,000	£540


Design choices

	HP only	HP + CHP + boiler
CAPEX	£136,000	£81,000
OPEX	£42,000	£25,000
SCOP	2.5	3.2
Security of supply	x	v
Sector coupling	x	v
SAP 2012 / el. grid marginal		
CO ₂ (tonnes/year)	163	131
CO ₂ reduction	15%	31%
SAP 10 (used by GLA)		
CO ₂ (tonnes/year)	73	118
CO ₂ reduction	56%	29%



El. 13.19p/kWh

Gas 3.94p/kWh

Plant selection – peak capacity



Plant selection – 150 apartments




- 150 apartments
- annual DHW and heating demand 600,000 kWh
- annual electricity demand 75,000 kWh

HP + CHP + boiler parallel design


High Load (100%)


Heat Source 1, 2 & 3

- 1 Heat Source 1 - CHP
- 2 Heat Source 2 - Heat Pump
- 3 Heat Source 3 - Peak Boiler




Heat Network – DHW





Return temperatures - 35kW DHW

Cold water temperature °C	10°	15°	20°
Primary temperature °C	Return temperature °C	Return temperature °C	Return temperature °C
60°C	19.97°C	23.25°C	26.7°C



Return temperatures - 35kW DHW

Cold water temperature °C	10°	15°	20°
Primary temperature °C	Return temperature °C	Return temperature °C	Return temperature °C
60°C	16.64°C	20.12°C	23.9°C

DHW Tapping Temperature – UK Clarification

■ HEATING, WATER HEATERS AND DATA CENTRES

SPECIAL FEATURES

This month: Water heater news; Rinnai updates on hydrogen appliances; Li-ion batteries in data centres

HSE clarifies risk guidance on instantaneous water heaters

DHW energy efficiency consultation to take place this month

The requirement for $\geq 50^{\circ}\text{C}$ delivery at outlets in M1 minute is applicable to systems incorporating hot-water storage, and does not necessarily apply for instantaneous water heaters. This means that the HSE has no fundamental objection to the reduction in temperature at outlets from HIUs.

- No Stored water (low risk)
- HIU = Combi boilers accepted temperatures
- Dish washing 45 sufficient

Response from Proctor & Gamble's R&D department:

"We test Fairy across a range of temperatures. However, 38-41 °C is in the normal temperature range that a consumer would use for this product."

Table 10 - Typical sizes of DHW HIU plate heat exchangers

Property type/suitability	Design Maximum occupancy	Number of bathrooms	Typical maximum power @ 10°C feed and 55°C DHW supply temperatures
Studio/1-bed	1	1	25-30 kW
Large 1-bed/ Small 2-bed	3	1	30-35 kW
Medium 2-bed/3-bed	4	2	35 kW

CP 1 (2020)

Space Heating





**Best practice – typically
not more than 25 W/m²**

**Space heating selection is critical
for achieving low system return
temperatures and efficient plant
and distribution infrastructure
sizing.**

Radiator Heating

Heat Network return temperature Target - 30 °C		
Heat Network return	Space heating flow	Space heating return
38.31 °C	55 °C	35 °C
31.81 °C	50 °C	30 °C


Selection of Heat Emitters



Pressure Independent Control Valve

Flow rate control over differential pressure

Flow rate [l/h]




Overflow resulting in high return temperatures

— Pressure Independent Radiator Valve

— Standard Radiator Valve

Differential pressure [kPa]

* At setting N (fully open)



Underfloor Heating

Heat Network return temperature Target - 30 °C		
Heat Network return	Space heating flow	Space heating return
35.08 °C	40 °C	35 °C
30.05 °C	35 °C	30 °C

Heating - UFH

- Avoid high thermal mass
- Avoid returns above 30°C




Screeded Floors					
UFH System Output (W/m²)					
Flow/Return Temperatures & UFH Pipe Centres (mm)					
65-55°C		60-50°C		55-45°C	
200 mm	300 mm	200 mm	300 mm	200 mm	300 mm

Primary side

- Reduce pipe size (possible with new guidelines)
- Insulate to avoid gains and losses

What Does 60/30 Scheme Look Like?

VWA(F/R)T for the **whole** year




Ultrasonic Meter Commissioning

Calculator



Ultrasonic
flow piece




Temperature
probes




**Meter
infrastructure for:**

- Billing
- Commissioning
- Monitoring

Commissioning on Direct Units



60/30 Commissioning Method with UMS



Commissioning Method with UMS

Each heat emitter

- Set the valve to the required setting
- The lock shield valve fully open
- Confirm the desired flow rate at the energy meter (adjust accordingly)
- Flow and return temps (may vary from design conditions)


Full load

- Confirm full load flow rate
- Flow and return temps (may vary from design conditions)




SAV office and warehouse

Monument House - Annual Heat Profile






Monument House - Heat Share




The Hyde Hendon

- 387 apartments + commercial
- 2 x 39 kW CHP + 2 x 43 kW HP + gas boilers




Ringkøbing District Heating



Summary - integrating heat pumps

- low return temperature
- large delta T for efficient building
- COP / SCOP
- CO₂ reduction
- CAPEX
- OPEX



HP + CHP + boiler

45% + 40% + 15%



SAV Trusted
Technology Partner

Thank you
for your attention

.....
Beata Blachut - Head of Technical Strategic Business Development

Any feedback or questions: info@sav-systems.com