


# Designing with large delta T heat pumps

SAV<sub>s</sub>

Adrian Rogers – Technical Manager, SAV Systems



# Heat Networks start with energy efficient buildings

## Reducing return temperature results in:

- Lower network pumping costs
- Lower distribution heat losses
- Higher energy centre heat generation outputs
- Maximise stored energy capacity

Climate Change Committee – 20% of population connected to a HN by 2050

Anchor loads – large commercial buildings are vital

Make buildings “Heat Network Ready”

# DHW Strategy

## Stored or Instantaneous?

- **Stored DHW:**
  - Large water volume
  - Legionella risk
  - Recirculation losses
  - High temperatures, low SCOP
  - Avoid coil calorifiers**




Figure 26 Plate heat calorifier

CIBSE Design Guide

- **Instantaneous:**
  - Point of use PHE / HIU
  - On-demand DHW, no recirc.
  - Low return temperature
  - Lower ASHP flow temperature
  - Higher SCOP

# Maximise Thermal Storage

160 m<sup>3</sup> Thermal Store @ Woking

8 m<sup>3</sup> Thermal Store @ 60/30  
Capacity = 280 kWh



**SAV<sub>s</sub>**



60 30

Capacity 5,568 kWh



70 30

Capacity 7,424 kWh

**33% Increase**

# Calculate Thermal Storage


Go beyond HP manufacturers “minimum”

Use thermal store to “**shave**” peak

Peak = Installed plant PLUS store discharge

Store recharges when network load is low

28% less plant, space, CAPEX, Noise, FLC..




In the example above, peak is shaved by 28%

- 490kW network peak
- 349kW ASHP
- 8000L thermal storage


# Variable Tariffs

- High carbon electricity is expensive
- Shift loads to avoid peaks
- On-site PV is free
- Convert surplus electricity into heat
- Store molecules, not electrons!

Average unit price for each 30 minute slot for the last 365 days



Half hour pricing for the last 7 days




# Hybrid/Bivalent systems

Hybrid plantrooms allows for the most efficient heat pump utilisation without oversizing

Multi-stage modulating boilers for top-up, system resilience and grid balancing

Heat pump installations for  
multi-unit residential buildings




AM16:2021

Thermonova | SAV<sub>s</sub>



# Hybrid Energy

A hybrid solution optimises heat pump operation and reduces the capital cost of the energy centre equipment. It minimises the space requirement for heat pumps and provides higher security and resilience of the design.



# First Generation Heat Pumps

- Designed around chiller circuit
- Small delta T (typ. 5° K)
- Constant flow rate
- Primary pump “by others”
- Synthetic refrigerants
- Flow temperature limitation
- Single stage of heat exchange
- Poor COP in heating systems

SAV<sub>s</sub> | DELTA



# Second Generation Heat Pumps

- Designed as **heat pump**
- **High** delta T (30°K like heat network)
- **Variable** flow rate
- Primary pump **internal**
- **Natural** refrigerants
- Flow temperature up to 70°C
- **Multiple** stages of heat exchange
- **High** COP for heating system

SAV<sub>s</sub> | DELTA




## Natural refrigerant R290 (propane)


Outstanding performance with ultra-low environmental impact (GWP 0.02).

# DELTA heat pumps

- Operating envelope = Capability
- 70°C flow at -15°C ambient
- 60°C flow at -20°C ambient
- Aim for largest possible DeltaT



How do we  
increase the  
efficiency of a  
condensing  
boiler?




# DELTA R290

## Large DeltaT

Exploit the DeltaT

Larger DeltaT = higher efficiency



# Hybrid Plant Assessment

Bivalent - Heat pump + E-Boiler

- 62% lower CAPEX
- 66% less space
- **SPF 3.04** including boiler

[Typical 5° DeltaT synthetic would be 2.4]

## SAV, DELTA Energy Centre Assessment

Project Ref SAV/HP/123456/AM/09 Mar 2026  
Project Name Blocks C, D & E Combined  
Proposal 1no SAV DELTA-HP4 Heat Pump + Electric Boiler  
Assessor AR



### Headlines

Source of emission factors:  
SAP 10.2

Weather Data Used (CIB SE TRY):  
1 London - South East

Project Estimated  
Heat Demand

**1,463,748 kWh**


Plantroom Temperatures

**Flow: 60°C  
Return: 32°C**


Heat Pump  
Constant Outlet Temperature

**60°C**

Whole System Seasonal Efficiency  
**SPF = 3.04**




Heat Pump Share  
**95.0%**



### Comparison with Notional Building


Carbon Footprint (kg/CO<sub>2</sub>)

**-80%**




Primary Energy kWh

**-62%**



Operating Cost (£)


**+9%**



\* Notional building with gas boiler


## 1st Generation Heat Pump – Small DeltaT

- 5°C DeltaT
- Very high flowrate
- Constant Flow
- 1 heat exchanger
- Legacy design
- COP 2.7 @ W55/A10




## 2<sup>nd</sup> Generation Heat Pump – DELTA-HP1

- 30°C DeltaT
- Variable (low) flowrate
- 3 heat exchangers
- 83% less flowrate
- 18% less electricity
- **COP 3.3 @ W60/A10**



# DELTA schematic



# Modular approach – easy to install




10no = 330 kW, 440A



1no = 351 kW, 232A

# F Gas Regulations Phasedown



SAV



Impact of Refrigerants Fact Sheet #2 (V.1)


## Refrigerants: Real GWP and PFAS

| Refrigerants / Brand Name | Type     | Composition                     | IPCC AR4 (2007) |                   | IPCC AR6 (2021) |                   | PFAS |
|---------------------------|----------|---------------------------------|-----------------|-------------------|-----------------|-------------------|------|
|                           |          |                                 | GWP 100 years   | Real GWP 20 years | GWP 100 years   | Real GWP 20 years |      |
| R32                       | HFC      | 100% R32                        | 650             | 2330              | 771             | 2690              | No   |
| R452B<br>Opteon XL55      | HFC/ HFO | 67% R32 / 7% R125 / 26% R1234yf | 681             | 2006              | 779             | 2275              | Yes  |
| R454B<br>Opteon XL41      | HFC/ HFO | 68.9% R32 / 31.1% R1234yf       | 448             | 1606              | 531             | 1854              | Yes  |
| R513A<br>Opteon XP10      | HFC/ HFO | 44% R134a / 56% R1234yf         | 629             | 1686              | 673             | 1823              | Yes  |
| R744                      | Natural  | CO <sub>2</sub>                 | 1               | 1                 | 1               | 1                 | No   |
| R290                      | Natural  | Propane                         | <1              | <1                | <1              | <1                | No   |

IPCC AR6 GWP over 20 years are the greatest immediate concern for global warming – all synthetic refrigerants score really badly on this timeframe

- ASHP Refrigerant GWP <150 by 2030
- F-Gas phase out by 2050

# Natural Refrigerant Choices



## R744 - CO2

- High flow temperature for potable DHW
- Very sensitive to return temperature
- High pressures = cost & complexity

## R600a - Isobutane

- High flow temp & high source temp.
- Second stage of cascade – W2W
- Domestic refrigeration
- Flammability class A3

## R290 - Propane

- ASHP heating in colder climates
- Compatible with flow/return temps.
- Flammability class A3

# Designing with Large Delta T heat pumps



Thermonova | SAV<sub>s</sub>





Thank you