
10 Brock St Net Zero

Jan 22

Twenty ne Engineering

Agenda



- Systems Overview
 - Chilled

6 off 1 MW Water cooled Chillers and shunt pumps

3 off Cooling Towers and Condense Pump

Primary Circulation pumps


- 3 Connections for 10 Brock St
- 1 Connection for 30 Brock St
- 2 Connections for 20 Brock St (2 PHX per connection)

Each Connection has it's own set of pumps to serve end user and suitable metering


- Systems Overview
 - Heating
 - 6 off 1 MW Gas Boiler and shunt pumps
 - 1 CHP unit and pumps
 - **Primary Circulation pumps**
 - **3 Connections for 10 Brock St**
 - 2 Connection for 30 Brock St
 - 2 Connections for 20 Brock St
 - 2 Connections for 175 Drummond St

Each Connection has it's own set of pumps to serve end user and suitable metering


Systems Overview Heating




Systems Overview Cooling




Systems Overview Cooling



Option 1 – Heat on Ambient loop



- ► Delivers a Zero Gas Operation (no Fossil Fuels) but will require large electrical use due to the requirement to heat the loop up
- ► Fails to recover any heat from any heat rejection



Option 2 – Ambient loop

- Delivers a Zero Gas Operation (no Fossil Fuels) and lowest electrical energy due to the heat recovery available
- ► As a result lowest carbon operation
- ▶ Reduces pump energy due to the operation of a single primary pump loop
- Occupier DX/ VRF (local cooling) can be connected to improve overall used energy

Option overview

Technology	kWh reduction	CO2 Reduction (Tonnes)	Cost (estimated)	
Hydrogen Boilers	none	TBC	£	750,000.00
,	,,,,,,,	-		,
Boiler Swap with ASHP	227,955	41.9	£	1,100,000.00
Heat Only Ambient Loop	379,926	69.9	£	2,000,000.00
Full Ambient loop	886,999	177.4	£	3,000,000.00

- Next Steps.
 - **□** Recommendations:

► Thank You

Any Questions

Twenty one Engineering