

11 MOUNTS BAY RD

ELECTRIFICATION OF HEATING

August 2025

INTRODUCTION & CIBSE READINESS

- Electrification of existing office building
- Demonstration of Readiness
 - Anticipate emerging risks
 - Climate Modelling
 - Absorb emerging risks
 - Improvements in resilience / system performance
 - Adapt to emerging risks
 - Reduction in emissions





11 MOUNTS BAY RD - SITE

- 5-storey building (plus ground floor podium level)
- Located Perth CBD
- Levels 1 – 5: Typical office floors,
- Total NLA: ~11,0000m²



EXISTING PLANT LAYOUT



All plant located on Level 6 plantroom

2x Air-Cooled Chillers

2x Boilers



Pumps

AHUs

Only existing ventilated plant area – Air-Cooled Chillers

No other external plant space

EXISTING WATERSIDE LAYOUT



2X AIR COOLED
CHILLERS AND 2X GAS
FIRED BOILERS ON THE
ROOF



NO COOLING TOWERS
/ TENANT CONDENSER
WATER LOOP



CHILLED WATER
CONNECTIONS
PROVIDED TO EACH
FLOOR FOR TENANT
CONNECTIONS





HEATING WATER
PROVIDED TO
PERIMETER VAV'S ON
ALL FLOORS FOR
REHEAT

EXISTING BOILERS

- 2x Raypak B1922 NCM/ID gas fired boilers
- 400 kW_R Heating Capacity each
- 5.1 L/s @ 75-55°C HW F&R Temperatures
- Gas Supply: 1922 MJ/hr each
- Small single phase power supply
- Dimensions (approx.): 2.6m x 0.8m each
- Weight (empty): 460 kg each

Total Existing Heating Capacity: 800 kW



Electric Heat Pumps -

OPTIONS

- **Option 1:**
High Temperature Air-Sourced Heat Pumps (like gas-fired boilers)
- **Option 2:**
Air Source Heat Pumps + Water-Sourced Heat Pumps (connected in series)
- **Option 3:**
Low Temperature Air-Source Heat Pumps (space efficient)



11 MBR – PLANT LOCATION - OPTIONS

Location A: Create a new plant deck (not preferred)


Location B: Delete 1 or both air-cooled chillers

Location C: Delete boilers and utilise space for low temperature heating water option.

11 MBR –OPTION 1


- High temp heat pumps
- Units large physically for heating output
 - Delete Air-Cooled Chiller

Won't work as building will lose both heating and cooling capacity




11 MBR –OPTION 2

- Delete Air-Cooled Chiller
 - Air-sourced heat pumps
- Delete Boilers
 - Water-sourced heat pumps
- Connected in series
- **Fits in space available**
- **Power upgrade (for Cooling)**
- **High cost (capital & demo)**
- **Poor Energy Efficiency (Low COP)**
- **Embodied Carbon waste**



11 MBR –OPTION 3

- Delete Air-Cooled Chiller
 - Air-sourced heat pumps
- Fits in space available
- No power upgrade
- Better Energy Efficiency
- Reduced Embodied Carbon
- Lower temp = heating coil replacement?



OPTIONS SUMMARY

	OPTION 1 (High temp HP's)	OPTION 2 (Internal + external)	OPTION 3 (Low temp HP's)
Internal Plant Area Required?	N/A		N/A
External Plant Area Requirement (Rank)	3	2	1
High Temperature HW			
Heating and Cooling?			
COP (Rank)	2	3	1
Unit Cost (Rank)	3	2	1

11 MBR – PLANT LOCATION - OPTIONS

Location A: Create a new plant deck (not preferred)

Location B: Delete 1 or both air-cooled chillers

Location C: Delete boilers and utilise space for low temperature heating water option.



BUT WAIT...

- Feedback from site states boilers are never both running at the same time
- Run at low loads for the majority of the year.
- Maximum operational heating load **~400kW.**





11 MBR – REDESIGN

- Delete Gas-Fired Boilers
- Small Modular Heat Pumps
- Buffer Tanks
- Can fit within access hatch into plantroom
 - No crane lift required




HEAT LOAD ANALYSIS

- IES Model – peak heating load **~350kW**
- Cooling Dominant



IS A POWER UPGRADE REQUIRED?

- Peak Power Consumption Occurs at Peak Cooling
(not simultaneous heating + cooling)




DROP IN HEATING WATER TEMPERATURE

- Proposed heat pumps can only supply 55°C
- Existing heating system oversized = oversized coils
- We believe existing heating coils could meet heating demand with reduced water flow temperature

Wanted to test this in practice – turned down the boiler supply temperature to 55°C and monitored space temp on BMS


BMS RESULTS

- Heating water flow temperature reduced
- Ran at 55°C over 1 winter month





BMS RESULTS

- Space temperature (Worst case/South zone during Winter week)



THERMAL STORAGE


- Buffer Tanks
- Charging overnight to higher water temperatures
- Accounts for derating of heat pumps at lower ambient temperatures
- Maximising efficiency of units



BENEFITS OF ELECTRIFICATION

- Electrification = “greener”?
- COP of ~3:
 - currently the CO₂ emissions of gas heating ~ CO₂ emissions of electric heat pumps (based upon current CO conversion coefficients for Perth)
 - Grid is rapidly becoming cleaner so will only improve
- Reduced Running Costs
- Less harmful atmospheric emissions

South West Interconnected System (SWIS) Emissions Factors



Source: Historical Greenhouse & Energy Reporting - Australia's Emissions Projections 2021

FURTHER POINTS FOR CONSIDERATION

- No “one size fits all” solution
- Reviewing heating loads not just like for like replacement
- Consideration of heating **and** cooling – need best fit to match heating and cooling load profiles
- Buffer tanks
 - provide minimum system volume
 - thermal storage benefits.

THANK YOU