

Lochinvar Ltd

LZCSolutions

Solar Thermal and its Integration with Domestic Hot Water systems
Presentation to CIBSE/ASHRAE Group 10TH December 2008




David Pepper- **Managing Director Lochinvar Ltd**

Steve Addis - **Product Manager L.Z.C products**






Why solar thermal

- Environmental factors**
 - Growing legislation
 - Green lobby
- Rising energy costs**
- People power**



Why solar thermal

- A well constructed solar thermal domestic hot water package will provide a sustainable reliable source of domestic hot water for many years without the need for costly ongoing maintenance.
- **It will:**
 - Reduce the Carbon footprint of the building
 - Reduce the buildings reliance on fossil fuels
 - Reduce the energy bills of the building

Basic System Design

- **System Components**
- **Sizing Solar Systems**
- **Integration With DHW Systems**

System Components

A Solar Thermal DHW system requires:

- A Solar collector
- Storage vessel or Heat Exchanger
- Pipework
- Control system
- Primary heat source



System Components

Solar collectors

There are 3 types

- Unglazed
- Flat plate
- Evacuated tube



Solar Collectors

• Flat Panel v Evacuated Tube

Flat Panel

- Simple design
- Cheaper
- Can be roof integrated
- Heavier
- Larger surface area required
- Less efficient


Evacuated Tube

- High efficiency even on cloudy days
- Smaller surface area
- Lightweight
- Repairable
- Seen as delicate
- Can need higher maintenance




Solar Collectors

Typical flat plate collector




Solar Collectors

- Typical evacuated tube collector



Solar Collectors

- Evacuated tube collector principles



Solar Collectors

- All solar collectors must be certified to BSEN 12975
- Look for the solar key mark



Solar irradiation




Chart showing solar irradiation in UK (W/m²) on collector surface at 30° facing south




Collector Efficiency

- Collector efficiency consists of
- Absorber efficiency average 85%
- Minus absorber emissions 2%-14% dependant upon insulation and selective coating
- **Collector efficiency will change according to ΔT between collector fluid temperature and outside air.**



Collector Efficiency

Collector efficiency		Input in green fields
Optical efficiency, η_0 :		0.87
1st order heat loss coefficient, a_1 :		1.55 W/(m ² ·K)
2nd order heat loss coefficient, a_2 :		0.006 W/(m ² ·K ²)
Temperature difference between collector fluid and ambient, $T_m - T_a$:		30 K
Solar irradiance on collector plane, G :		800.0 W/m ²
Collector efficiency, η :		0.718




Jan Erik Nielsen, ESTIP, 2006



Collector Efficiency

Collector efficiency		Input in green fields
Optical efficiency, η_0 :		0.87
1st order heat loss coefficient, a_1 :		0.98 W/(m ² ·K)
2nd order heat loss coefficient, a_2 :		0.003 W/(m ² ·K ²)
Temperature difference between collector fluid and ambient, $T_m - T_a$:		30.0 K
Solar irradiance on collector plane, G :		200.0 W/m ²
Collector efficiency, η :		0.427



Jan Erik Nielsen, ESTIP, 2006



Collector Efficiency

- Care should be taken to ensure the collectors are sited correctly.
- South facing @30-40 degrees
- Avoid shading



System Components


Storage vessel or Heat Exchanger

- Must be sized accurately for collectors
- Usually fitted next to the primary heat source
- Heat exchangers used for specialized applications




Solar store

- Pre-heat store




Solar store

- Twin coil calorifier



Pipe-work

- Must be sized to suit the individual project
- Must be constructed from materials capable of withstanding high temperatures (160c) and pressures (6bar) pressfit !
- Should incorporate appropriate safety valves and expansion vessel.



Controls

Lochinvar

Controls By-pass arrangement

3 port valve closed until temp B exceeds demand temp

Lochinvar

Controls By-pass arrangement

3 port valve opens when temp B reaches demand temp

Lochinvar

Controls Heat-dump arrangement

Fan convector


Solar collectors

3 port valve closed until solar store satisfied

Solar store

Lochinvar

Controls Heat-dump arrangement




Controls legionella control


- Legionella colonisation can be a risk within the solar vessel, especially during spring/autumn when temperatures within the vessel will be lower.
- Temperature control
- Mechanical control




Legionella control-temperature



Legionella control-temperature



Legionella control-mechanical



Primary heat source

- Will still do a large percentage of the D.H.W demand
- Efficiency of appliance important
- Consider condensing



Condensing Technology



- Gross efficiencies – up to 98%
- Hot water recovery rates from 700 to 10,000 l/hr




Sizing of solar systems

Project Criteria

- In order to provide an accurate sizing the following information is required:
 - Daily hot water demand
 - **SOLAR FRACTION** required
 - Post code of the building
 - Type of building
 - Number of occupants per day
 - Roof space available and orientation/ pitch of roof



T-SOL sizing calculation



20 x CPC 6 OEM
Total Gross Surface Area: 22.80 m²
Acrum 47
Inc: 30°

3.5 m³/Day
43 °C

Eco-Knight 115 direct fired water



SSC1500

Results of Annual Simulation

Installed Collector Power:	15.36 kW
Collector Surface Area Irradiation:	22.47 kWh / 1,123.7 kWh/m ²
Energy Produced by Collectors:	13.05 MWh / 647.26 kWh/m ²
Energy Produced by Collector Loop:	13.05 MWh / 648.03 kWh/m ²
DHW Heating Energy Supply:	49.08 MWh
Solar Contribution to DHW:	11 MWh
Energy from Auxiliary Heating:	38.05 MWh


Natural Gas (G) Savings:	1,599.7 m ³
CO ₂ Emissions Avoided:	3,279.22 kg
DHW Solar Fraction:	28.6 %
Fractional Energy Savings (Dh 12075):	28.8 %
System Efficiency:	57.8 %

• Typical results, Bristol

T-SOL sizing calculation



Solar Energy Consumption as Percentage of Total Consumption



1,200
1,000
800
600
400
200
100



Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec

Solar System 12,967 kWh
Total Energy Consumption 48,949 kWh

System efficiency



- System efficiency is dependant upon:
 - Type of collectors used
 - Temperature of the DHW system
 - Installation of collectors
 - Solar fraction
 - Correct sizing of solar storage vessel
 - Typically around 50%-60%

Integration

The main methods of integration are:

- Domestic hot water systems
 - Twin coil calorifier
 - Pre-heat store
- Swimming pools
 - Heat exchanger

Maintenance

- Panels are generally self cleaning due to angle sited
- Pressure within the system checked annually
- Circulation pump checked annually
- Visual inspection of panels every 3-5 years



Thank you for listening

Have you any questions?



e-mail: sales@lochinvar.ltd.uk
www.lochinvar.ltd.uk

