

Assessing natural ventilation flows - laboratory and analytical modelling

shaun.fitzgerald@breathingbuildings.com


T +44 1223 450060

Contact Theatre Before




Before renovation

Contact Theatre, after renovation











Concept - displacement ventilation when warmer inside


Multiple Stacks



Area of lower aperture

Height of stacks

Contact Theatre, Studio




- Stack 1
- Stack 2
- Stack 3
- Stack 4
- external
- top of theatre

Evening/
Morning
Warmer
inside
than
outside


Stack 3 inflow?

Stack 2 also inflow later?


Stack 1 outflow





Stack 2 outflow



Stack 3 inflow




Stack 4 outflow



Stack 3 inflow → balance of base and stack areas



Detailed section



**Associated
Architects**





 **worcestershire**
countycouncil




Hagley School



Distributed heating at base



Flow calculation for outflow from stack





$$\text{Vol flux} = f(H-h_B)$$




Note $h_B > h_A$

Flow calculation for inflow through stack






Localised heating at base



Two layer stratification


Volume flux from plume
to upper layer


Localised heating at base




Pure hot layer outflow

Mixed outflow







Pure "hot" layer outflow






Mixed outflow




Buoyancy in stack, function of average density
 Conservation of buoyancy
 Volume flux through stack driven by buoyancy
 Volume flux in plume MTT






-ve buoyant plume from B
 +ve buoyant plume from "heater"


Entrainment by descending plume
 Virtual origin (Turner, Buoyancy
 Effects in Fluids)




II




III




III




IV




I




II




III




IV




V




$$A = A^* / (\lambda^{3/2} H^2) = 0.1$$






REGIME i




REGIME ii










V







||







III







IV







i





ii





Collaborators

- Andy Woods + BPI team
- Mark Tucker, Purdue

Building and Environment **43**, 1719-1733

Applications to hybrid buildings