





ENERGY & CARBON EFFICIENCY

WHAT PART CAN LIFTS PLAY?


Prepared for:



EMBODIED CARBON



A changing carbon story



A “best in class”, low-carbon sustainable development must consider embodied carbon impacts.

Industry Frameworks & Targets

UK GBC
Together for a better built environment

ADVANCING NET ZERO

**Net Zero Carbon Buildings:
A Framework Definition**

APRIL 2019

Advancing Net Zero Programme Partners

Lead Partner: REDECO

Programme Partners: bam, Berkeley Group, GROSVENOR, HOARE LEA, JLL

RIBA
2030
CLIMATE
CHALLENGE

Sign up to take the RIBA
2030 Climate Challenge at
www.architecture.com/2030challenge

RIBA
Architecture.com

LETI Embodied Carbon Primer

Supplementary guidance to the Climate Emergency Design Guide

Build collaboratively
Build for the future
Build low carbon
Build less
Build light
Build wise

Primary Actions

LONDON ENERGY TRANSFORMATION INITIATIVE

MAYOR OF LONDON

**Whole Life-Cycle Carbon Assessments
guidance**



Pre-consultation draft

Greater London Authority (GLA) Whole Life Carbon Assessment

GLA WLCAG Benchmarks and Targets - Commercial

| Benchmark Type | EN 15978 Modules | Commercial EC Intensity (kgCO ₂ e/m ² GIA) |
|----------------------------|------------------|---|
| Typical Benchmark | A-C | 1,300-1,500 |
| | A1-A5 | 900-1,000 |
| | B & C | 400-500 |
| GLA Aspirational Benchmark | A-C | 800-900 |
| | A1-A5 | 550-600 |
| | B & C | 250-300 |

LCA process focuses approach



105 Victoria Street

Westminster, London

Office, retail & amenity

60,000 m² GIA

2 levels of RC basement

15 storeys above ground

Steel frame & precast concrete plank

Terracotta unitised curtain walling

2,500 m² of urban greening

Heat-pump-led all-electric building services approach.


BREEAM & WELL assessments.

Net-zero carbon aims.

Baseline embodied carbon

1,165 kgCO₂e/m² GIA





- Facilitating Works (0.02%)
- Substructure (8%)
- Frame, Upper Floors, Roof, Stairs (43%)
- Façade & External Doors (7%)
- Internal Walls Doors (2%)
- Finishes (12%)
- FF&E (1%)
- Services (14%)
- External Works (0.03%)
- Site Impacts (5%)
- Refrigerants (7%)

1,165 kgCO₂e/m² GIA




Building Services & Lifts

Example split of MEPH embodied carbon

Example – broken down by RICS NRM 1 categories

| RICS NRM Element | Impact (tCO2e/60 years, A-C) | % of total |
|-----------------------------------|------------------------------|------------|
| 5.1 - Sanitaryware | 805 | 8% |
| 5.3 - Disposal Installations | 97 | 1% |
| 5.4 - Water Installations | 164 | 2% |
| 5.6 - Space Heating & AC | 1,569 | 16% |
| 5.7 - Ventilation | 889 | 9% |
| 5.8 - Electrical Installations | 3,788 | 38% |
| 5.9 - Fuel Installations | 31 | 0.3% |
| 5.10 - Lifts & Conveyors | 777 | 8% |
| 5.11 - Fire & Lightning | 130 | 1% |
| 5.12 - Comms, security & controls | 3 | 0.03% |
| B1 - Refrigerants | 1,819 | 18% |





Building services equipment & products have the poorest availability of EPD data

Availability of EPD for Lifts


Better availability than typical MEP equipment



Schindler 3300



Otis GEN2




KONE Monospace

Material Breakdowns

| MATERIAL | MASS [kg] | MASS [%] |
|--|---------------|----------|
| Ferrous metals (zinc coated steel, stainless steel, cast iron) | 10 995,3 | 87,5 |
| Inorganic materials (concrete, glass) | 984,4 | 7,8 |
| Plastics & Rubbers | 323,8 | 2,6 |
| Non-ferrous metals (aluminum, copper) | 152,17 | 1,2 |
| Electric & Electronic equipment | 74,6 | 0,6 |
| Batteries & Accumulators | 17,2 | 0,1 |
| Lubricants (oils, greases), paintings, coatings, adhesives and fillers (glues) | 7,7 | 0,1 |
| Organic materials (paper, wood, cardboard) | 6,0 | 0,0 |
| Other materials | 2,2 | 0,0 |
| Total mass | 12 563 | |
| Mass per 1 tkm | 1,48 | |

- Ferrous metals
- Inorganic materials
- Plastic & Rubbers
- Non-ferrous metals
- Electric & Electronic equipment
- Batteries & Accumulators
- Lubricants, paintings, coatings, adhesives and fillers
- Organic materials
- Other materials



Otis GEN2 Example

ADVANCED TECHNOLOGY IS A STANDARD AT OTIS

A technical drawing of an Otis GEN2 elevator machine. Three callouts, labeled A, B, and C, point to specific components of the machine. Callout A points to the polyurethane-coated flat steel belts, callout B points to the gearless machine, and callout C points to the Regen Drive technology. The drawing also shows the LED lighting for the car operating panel and the cabine ceiling.

- + A. Polyurethane coated flat steel belts (no lubricant)
- + B. Gearless machine (energy efficient, no lubricant, space-saver)
- + C. Regen Drive technology (electricity generation)
- + LED lighting: Car Operating Panel / Cabine ceiling

Assess options for reduction



11 tCO₂e/tonne

Global average
aluminium impact



ES Process



Interrogate supply chain to find alternatives



0.18 tCO₂e/tonne


C40/50 CEM1
UK-sourced



GGBS replace OPC



Options for cement-free?



2.5 tCO₂e/tonne

UK BF/BOF steel
~20-25% scrap



BOF vs EAF



Rolled vs. plate



Source, manufacturers
& supply chain

Working to improve MEPH LCA at Sweco

- Working to create **Sweco database** to establish baseline impacts for generalized typical services solutions to inform clients.
- **Better utilization of BIM** – services engineers providing Revit takeoffs as part of RIBA stage processes
- **Integrating LCA into our early-stage optioneering studies** and making it a key factor in the decision-making process
- Taking advantage of the advent of new tools in early 2021 – recent release of **CIBSE TM65**.

Embodied carbon in building services: a calculation methodology



TM65: 2021



OPTIMIZATION OF OPERATIONAL ENERGY (PART L / DFP / CIBSE TM54 FRAMEWORKS)


UK PERFORMANCE GAP EXPLAINED

Part L Regulation carbon emission is based upon “Regulated Energy”

What is Regulated Energy ?

“Fixed Building Services”


- Lighting Energy
- Pumps & Fans Energy
- Cooling Energy
- Heating Energy
- Domestic Hot Water



What is Un-Regulated Energy ?

“ Small Power or Process Power or End User Energy”


- Computers and Data centres equipment
- Microware, Ovens & Gas hobs
- Lifts and Escalators
- Printers & Photocopiers
- Process plants e.g. commercial kitchens / Laundry



Design for Performance

Part L Performance Gap


Office Energy Intensity by EPC rating 2018/19
 Energy Intensity ($\text{kWh}_{\text{elec.eq}}$ per m^2 per year)



*Energy intensity measured in $\text{kWh}_{\text{elec.eq.}}$ per m^2 per year. Dataset includes 1,038 properties.





Part L Model versus TM54 Estimate versus Actual
 Source CIBSE




Performance Calculations and Associated Gaps

Understanding the Performance Gap – Case Study, Office Building in London -2017

Compliance modelling



Performance modelling



6 kWh/m²/yr.

Note: Example of results shown on the slides are based on CIBSE TM54 predication calcs done at RIBA stage 3 based on general assumptions and ASHRE profiles with error margin +15% subject to review at later stage.

Metrics

%

reduction CO2 emissions
(vs notional building)

Includes energy supply type
Comparison with a fixed building specification
Multiple influencing factors

kWh/m²/yr.



Energy Use Intensity
(EUI)

Energy supply agnostic
Measures energy 'at the meter'

UNDERSTANDING INDUSTRY BENCHMARKING FOR OFFICES

Energy Performance Targets

Industry Benchmarks



Net zero carbon: energy performance targets for offices

JANUARY 2020



REAL ESTATE ENVIRONMENTAL BENCHMARK: 2019 ENERGY SNAPSHOT

MARCH 2020

Defining net zero carbon

A new approach: LETI

Low energy use

- 1 Total Energy Use Intensity (EUI) - Energy use measured at the meter should be equal to or less than:

- **35 kWh/m²/yr** (GIA) for residential¹

For non-domestic buildings a minimum DEC B (40) rating should be achieved and/or an EUI equal or less than:

- **65 kWh/m²/yr** (GIA) for schools¹
- **70 kWh/m²/yr** (NLA) or **55 kWh/m²/yr** (GIA) for commercial offices^{1,2}


- 2 Building fabric is very important therefore space heating demand should be less than **15 kWh/m²/yr** for all building types.

Measurement and verification

- 3 Annual energy use and renewable energy generation on-site must be reported and independently verified in-use each year for the first 5 years. This can be done on an aggregated and anonymised basis for residential buildings.

Reducing construction impacts

- 4 Embodied carbon should be assessed, reduced and verified post-construction.³



Low carbon energy supply

- 5 Heating and hot water should not be generated using fossil fuels.
- 6 The average annual carbon content of the heat supplied (gCO₂/kWh) should be reported.
- 7 On-site renewable electricity should be maximised.
- 8 Energy demand response and storage measures should be incorporated and the building annual peak energy demand should be reported.

Zero carbon balance


- 9 A carbon balance calculation (on an annual basis) should be undertaken and it should be demonstrated that the building achieves a net zero carbon balance.
- 10 Any energy use not met by on-site renewables should be met by an investment into additional renewable energy capacity off-site OR a minimum 15 year renewable energy power purchase agreement (PPA). A green tariff is not robust enough and does not provide 'additional' renewables.

Design for Performance

Background to Initiative

Australia's Design for Performance Culture: NABERS

- Launched in 1999, an operational energy performance assessment.
- Provides a simple metric to investors, owners and occupiers on how efficiently a building is being operated in-use.



Resulted in *Design for Performance* not compliance



NABERS: National Australian Built Environment Rating System


The screenshot shows the BBP (Better Buildings Partnership) website. At the top, there are navigation links: MEMBER LOGIN, SEARCH, OUR RESOURCES, OUR MEMBERS, OUR PROJECTS, and ABOUT US. Below the navigation is a section titled "Our Members" which displays a grid of logos for various member organizations. The logos include:

- Aberdeen Standard Investments
- AVIVA INVESTORS
- Blackstone
- BMO Real Estate Partners
- British Land
- bruntwood
- CANARY WHARF GROUP PLC
- C&R CAPITAL & REGIONAL
- CBRE GLOBAL INVESTORS
- CLS Holdings plc
- DERWENT LONDON
- DWS
- EDMOND DE ROTHSCHILD
- Federated Hermes
- FRASERS PROPERTY
- GREAT PORTLAND ESTATES
- GROSVENOR
- Hammerson
- intu
- Landsec
- LaSalle INVESTMENT MANAGEMENT
- Legal & General INVESTMENT MANAGEMENT
- lendlease
- LOGICOR
- LOW CARBON WORKPLACE Partnership
- M&G REAL ESTATE
- NORGES BANK INVESTMENT MANAGEMENT
- nuveen REAL ESTATE
- PICTON
- ROYAL LONDON ASSET MANAGEMENT
- Schroders
- SEGRO WHERE BUSINESS WORKS
- Shaftesbury
- THE CROWN ESTATE
- Transport for London
- WORKSPACE

At the bottom of the page, there are links for "CONNECT WITH US" (Twitter, LinkedIn), "SIGNUP FOR OUR NEWSLETTER" (with a search bar and "SUBMIT" button), and "CONTACT US".

Better Building Partnership UK & NABERs

Office Building Benchmarking targets & terminology



Energy performance targets

UK GBC interim targets Vs Standard BCO 2014 Building

225 kWh_e/m²/annum
(Real Estate Environmental Benchmark)

| Scope | Metric | Interim Targets | | | Paris Proof Target |
|-----------------------|---|-----------------|-----------|-----------|--------------------|
| | | 2020-2025 | 2025-2030 | 2030-2035 | 2035-2050 |
| Whole building energy | kWh _e /m ² (NLA) / year | ● 160 | 115 | 90 | 70 |
| | kWh _e /m ² (GIA) / year | 130 | 90 | 70 | 55 |
| | DEC rating | C90 | C65 | B50 | B40 |
| Base building energy | kWh _e /m ² (NLA) / year | 90 | 70 | 55 | 35 |
| | kWh _e /m ² (GIA) / year | 70 | 55 | 45 | 30 |
| | NABERS UK star rating | 4.5 | 5 | 5.5 | 6 |
| Tenant energy | kWh _e /m ² (NLA) / year | 70 | 45 | 35 | 35 |




NLA = net lettable area GIA = gross internal area

How Ambitious are These Targets?

Understanding Lift Contribution




| Scope | Metric | Interim Targets | | | Paris Proof Target |
|-----------------------|---|-----------------|-----------|-----------|--------------------|
| | | 2020-2025 | 2025-2030 | 2030-2035 | 2035-2050 |
| Whole building energy | kWh _e /m ² (NLA) / year | 160 | 115 | 90 | 70 |
| | kWh _e /m ² (GIA) / year | 130 | 90 | 70 | 55 |
| | DEC rating | C90 | C65 | B50 | B40 |
| Base building energy | kWh _e /m ² (NLA) / year | 90 | 70 | 55 | 35 |
| | kWh _e /m ² (GIA) / year | 70 | 55 | 45 | 30 |
| | NABERS UK star rating | 4.5 | 5 | 5.5 | 6 |



What This Means for Lift Industry ?

Change in the energy story

- Moving from unregulated to regulated energy consumption as part of Base-build Energy in NABERS-UK;
- Higher % of the annual energy usage as HVAC systems and small power are challenged to reduce energy consumption;
- More focus on how to predicted operational energy at design stage using different framework and methods;
- Additional optimization and post occupancy evaluation (POE) data will be available as a result of the NABERS-UK validation process and the GLA Be Seen Policy




Operational Energy Consumption Prediction Framework

CIBSE TM54 -2013




Based on CIBSE Guide D & BS ISO DIS 25745-1 (2012)

BREEAM 2018 – ENE06



Focusing on motor drivers optimization using ISO DIS 25745-2 (2015)

NABERS UK -2020



Based on ISO DIS 25745-2 (2015) With simplified equations

← Lift energy consumption in a single lift approach without considering of controlling and grouping algorithms →

LIFT ENERGY CONSUMPTION – CASE STUDY

Case Study – TM54 Approach

7.4 Step 4: Evaluating energy use for lifts and escalators

7.4.1 Lifts

CIBSE Guide D (CIBSE, 2012) includes a calculation for lift energy use. This methodology requires some detailed information that may not be readily available for designers.

Alternatively, many lift manufacturers have proprietary energy calculators that can estimate annual energy use with fairly straightforward inputs.

The calculation quoted in CIBSE Guide D is from BS ISO/DIS 25745-1 (BSI, 2012). This calculation method uses the following formula to estimate lift energy use:

$$E_L = (S P t_h / 4) + E_{\text{standby}}$$

where E_L is the energy used by a single lift in one year (kW·h), S is the number of starts made per year, P is the rating of the drive motor (kW), t_h is the time to travel between the main entrance floor and the highest served floor from the instant the doors have closed until the instant they start to open (i.e. one half of a reference trip cycle) (h) and E_{standby} is the standby energy used by a single lift in one year (kW·h).

This equation relies on a number of assumptions:

- the building has a uniform floor population
- the number of up stops is equal to the number of down stops
- no allowance is made for regeneration
- no allowance is made for the actions of the traffic controller (single units only are considered)
- no significant number of stops are made below the main entrance floor.

The number of starts per day can be estimated from Table 3.

The location of the lifts and the accessibility of the stairs will make a difference to how frequently the lift is used.

Table 3 Lift duty (source: BS ISO/DIS 25745-1)

| Lift duty | Rating (starts/h) | Starts/day | Examples (days/week) |
|-----------|-------------------|------------|---|
| Low | 60 | <100 | Residential care (7), goods (5), library (6), entertainment centre (7), stadia (intermittent) |
| Medium | 120 | 300 | Office car parks (5), general car parks (7), residential (7), university (5), hotel (7), low-rise hospital (7), shopping centre (7) |
| High | 180 | 750 | Office (5), airport (7), high-rise hospital (7) |
| Intensive | 240 | 1000 | Headquarters office (5) |

This could be taken into account by adjusting the number of starts per day accordingly.

Evaluating operational energy performance of buildings at the design stage



TM54: 2013



Case Study – TM54 Approach

| Name | Type | Speed (m/s) | Lift travel (m) | Lift Duty | Starts per day | Number of starts/year | Motor (kW) | Time to travel lowest to highest floor (s) | Travel Time (h) | Time Spent Travelling (h) | Time Spent Standby (h) | Standby (kW) | Standby (kWh / yr) | Travelling (kWh / yr) | Total (kWh / yr) |
|--------|--------------------------|-------------|-----------------|-----------|----------------|-----------------------|------------|--|-----------------|---------------------------|------------------------|--------------|--------------------|-----------------------|------------------|
| PFL 01 | High Rise Passenger / | 4.0 | 94.300 | Intensive | 1000 | 260000 | 45 | 23.575 | 0.006549 | 1702.64 | 7057.36 | 0.10 | 706 | 19,155 | 19,860 |
| PL 02 | High Rise Passenger | 4.0 | 84.550 | Intensive | 1000 | 260000 | 45 | 21.138 | 0.005872 | 1526.60 | 7233.40 | 0.10 | 723 | 17,174 | 17,898 |
| PL 03 | High Rise Passenger | 4.0 | 80.325 | Intensive | 1000 | 260000 | 45 | 20.081 | 0.005578 | 1450.31 | 7309.69 | 0.10 | 731 | 16,316 | 17,047 |
| PFL 04 | High Rise Passenger / | 4.0 | 99.175 | Intensive | 1000 | 260000 | 45 | 24.794 | 0.006887 | 1790.66 | 6969.34 | 0.10 | 697 | 20,145 | 20,842 |
| PL 05 | Mid Rise Passenger | 2.5 | 53.550 | Intensive | 1000 | 260000 | 35 | 21.420 | 0.005950 | 1547.00 | 7213.00 | 0.10 | 721 | 13,536 | 14,258 |
| PL 06 | Mid Rise Passenger | 2.5 | 53.550 | Intensive | 1000 | 260000 | 35 | 21.420 | 0.005950 | 1547.00 | 7213.00 | 0.10 | 721 | 13,536 | 14,258 |
| PL 07 | Mid Rise Passenger | 2.5 | 49.325 | Intensive | 1000 | 260000 | 35 | 19.730 | 0.005481 | 1424.94 | 7335.06 | 0.10 | 734 | 12,468 | 13,202 |
| PL 08 | Mid Rise Passenger | 2.5 | 49.325 | Intensive | 1000 | 260000 | 35 | 19.730 | 0.005481 | 1424.94 | 7335.06 | 0.10 | 734 | 12,468 | 13,202 |
| PL 09 | Low Rise Passenger | 1.6 | 34.175 | Intensive | 1000 | 260000 | 20 | 21.359 | 0.005933 | 1542.62 | 7217.38 | 0.10 | 722 | 7,713 | 8,435 |
| PL 10 | Low Rise Passenger | 1.6 | 34.175 | Intensive | 1000 | 260000 | 20 | 21.359 | 0.005933 | 1542.62 | 7217.38 | 0.10 | 722 | 7,713 | 8,435 |
| PL 11 | Low Rise Passenger | 1.6 | 29.950 | Intensive | 1000 | 260000 | 20 | 18.719 | 0.005200 | 1351.91 | 7408.09 | 0.10 | 741 | 6,760 | 7,500 |
| PL 12 | Low Rise Passenger | 1.6 | 29.950 | Intensive | 1000 | 260000 | 20 | 18.719 | 0.005200 | 1351.91 | 7408.09 | 0.10 | 741 | 6,760 | 7,500 |
| PL 13 | Low Rise Passenger | 1.6 | 29.950 | Intensive | 1000 | 260000 | 20 | 18.719 | 0.005200 | 1351.91 | 7408.09 | 0.10 | 741 | 6,760 | 7,500 |
| GL01 | Goods Lift | 1.6 | 49.925 | High | 750 | 195000 | 35 | 31.203 | 0.008668 | 1690.17 | 7069.83 | 0.10 | 707 | 14,789 | 15,496 |
| GL02 | Goods Lift | 2.0 | 99.175 | High | 750 | 195000 | 40 | 49.588 | 0.013774 | 2685.99 | 6074.01 | 0.10 | 607 | 26,860 | 27,467 |
| CL01 | Cycle Lift | 1.0 | 4.225 | Medium | 50 | 13000 | 10 | 4.225 | 0.001174 | 15.26 | 8744.74 | 0.10 | 874 | 38 | 913 |
| LL01 | Lorry Lift | 0.275 | 10.100 | Medium | 66 | 20592 | 180 | 36.727 | 0.010202 | 210.08 | 8549.92 | 0.50 | 4,275 | 9,454 | 13,729 |
| LL02 | Lorry Lift | 0.275 | 10.100 | Medium | 66 | 20592 | 220 | 36.727 | 0.010202 | 210.08 | 8549.92 | 0.50 | 4,275 | 11,554 | 15,829 |
| SL 01 | Shuttle Passenger | 1.6 | 14.800 | High | 750 | 195000 | 20 | 9.250 | 0.002569 | 501.04 | 8258.96 | 0.10 | 826 | 2,505 | 3,331 |
| SL 02 | Shuttle Passenger | 1.6 | 14.800 | High | 750 | 195000 | 20 | 9.250 | 0.002569 | 501.04 | 8258.96 | 0.10 | 826 | 2,505 | 3,331 |
| PL 13 | High Rise Passenger | 6.0 | 13.450 | Intensive | 1000 | 260000 | 55 | 2.242 | 0.000623 | 161.90 | 8598.10 | 0.10 | 860 | 2,226 | 3,086 |
| PL 14 | High Rise Passenger | 6.0 | 13.450 | Intensive | 1000 | 260000 | 55 | 2.242 | 0.000623 | 161.90 | 8598.10 | 0.10 | 860 | 2,226 | 3,086 |
| PL 15 | High Rise Passenger | 6.0 | 131.750 | Intensive | 1000 | 260000 | 55 | 21.958 | 0.006100 | 1585.88 | 7174.12 | 0.10 | 717 | 21,806 | 22,523 |
| PL 16 | High Rise Passenger | 6.0 | 131.750 | Intensive | 1000 | 260000 | 55 | 21.958 | 0.006100 | 1585.88 | 7174.12 | 0.10 | 717 | 21,806 | 22,523 |
| PL 17 | Mid Rise Passenger | 5.0 | 89.125 | Intensive | 1000 | 260000 | 45 | 17.825 | 0.004951 | 1287.36 | 7472.64 | 0.10 | 747 | 14,483 | 15,230 |
| PL 18 | Mid Rise Passenger | 5.0 | 89.125 | Intensive | 1000 | 260000 | 45 | 17.825 | 0.004951 | 1287.36 | 7472.64 | 0.10 | 747 | 14,483 | 15,230 |
| PL 19 | Mid Rise Passenger | 5.0 | 89.125 | Intensive | 1000 | 260000 | 45 | 17.825 | 0.004951 | 1287.36 | 7472.64 | 0.10 | 747 | 14,483 | 15,230 |
| PL 20 | Mid Rise Passenger | 5.0 | 89.125 | Intensive | 1000 | 260000 | 45 | 17.825 | 0.004951 | 1287.36 | 7472.64 | 0.10 | 747 | 14,483 | 15,230 |
| FFL 01 | Passenger / Firefighters | 3.0 | 148.575 | Medium | 300 | 78000 | 25 | 49.525 | 0.013757 | 1073.04 | 7686.96 | 0.10 | 769 | 6,707 | 7,475 |
| FFL 02 | Passenger / Firefighters | 3.0 | 142.595 | Medium | 300 | 78000 | 25 | 47.532 | 0.013203 | 1029.85 | 7730.15 | 0.10 | 773 | 6,437 | 7,210 |
| GL03 | Goods / Passenger | 3.0 | 161.295 | High | 750 | 195000 | 60 | 53.765 | 0.014935 | 2912.27 | 5847.73 | 0.10 | 585 | 43,684 | 44,269 |

Escalators 27,697

Total kWh/yr 448,822

Area m² 66,707

kWh/m²/yr 6.73

Case Study – Modelling Approach



High-rise lift group

| Name | Speed (m/s) | Lift travel (m) | Lift Duty | Starts per day | Number of starts/year | Motor (kW) | Time Spent Travelling (h) | Time Spent Standby (h) | Standby (kW) | Standby (kWh / yr) | Travelling (kWh / yr) | Total (kWh / yr) | kWh / operational d |
|------------|-------------|-----------------|-----------|----------------|-----------------------|------------|---------------------------|------------------------|--------------|--------------------|-----------------------|------------------|---------------------|
| PFL01 | 4.0 | 94.300 | Intensive | 1000 | 260000 | 45 | 1702.64 | 7057.36 | 0.10 | 706 | 19,155 | 19,860 | 76 |
| PL02 | 4.0 | 84.550 | Intensive | 1000 | 260000 | 45 | 1526.60 | 7233.40 | 0.10 | 723 | 17,174 | 17,898 | 68 |
| PL03 | 4.0 | 80.325 | Intensive | 1000 | 260000 | 45 | 1450.31 | 7309.69 | 0.10 | 731 | 16,316 | 17,047 | 65 |
| PFL04 | 4.0 | 99.175 | Intensive | 1000 | 260000 | 45 | 1790.66 | 6969.34 | 0.10 | 697 | 20,145 | 20,842 | 79 |
| 288 | | | | | | | | | | | | | |

Case Study – Modelling Approach

- Group control
- Regenerative drives
- Siikonen full day (24-hr) office demand template
- Occupancy set to 70% of base build design (NABERS)

| | Car 1 | Car 2 | Car 3 | Car 4 |
|--------------------------|-------|-------|-------|-------|
| kW drive off | 0.1 | 0.1 | 0.1 | 0.1 |
| kW drive on | 0.1 | 0.1 | 0.1 | 0.1 |
| kW 0% load Up | -11 | -11 | -11 | -11 |
| kW 25% load Up | -0.2 | -0.2 | -0.2 | -0.2 |
| kW 50% load Up | 13.4 | 13.4 | 13.4 | 13.4 |
| kW 75% load Up | 28.3 | 28.3 | 28.3 | 28.3 |
| kW 100% load Up | 43.1 | 43.1 | 43.1 | 43.1 |
| kW 0% load Down | 34.3 | 34.3 | 34.3 | 34.3 |
| kW 25% load Down | 19.5 | 19.5 | 19.5 | 19.5 |
| kW 50% load Down | 5.1 | 5.1 | 5.1 | 5.1 |
| kW 75% load Down | -6.7 | -6.7 | -6.7 | -6.7 |
| kW 100% load Down | -17.1 | -17.1 | -17.1 | -17.1 |



The ISO energy classification of a lift

ISO energy labels

Calculating the energy consumed

The UK and the EU enact new energy labels in September 2021.
Lifts are left out does it matter?

Presented by
Dr Gina Barney
Principal, *Gina Barney Associates*



Vertical transportation
In a Nutshell

0:05 / 2:16



Summary & Questions

Are you ready?

- Introduction of maximum target values for lift motor rating similar based on type similar to air handling units;
- Participate in writing the new CIBSE TM54 and refining the NABERS UK approach to lifts;
- Define an approach to model the lift energy consumption;
- Introduction of Energy Performance Certificates verified by independent third party as part of lift technical submission;
- Detailed review of sub-metering data and POE results to understand the impact of operation and maintenance.

