


Energy Efficient School Design

SAV_®



Our Technology Partners

SAV_s | DELTA



Metering Solutions

kamstrup




Hydronic Solutions

Danfoss




Communal and District Heat Pumps

Thermonova



Mechanical Ventilation with Heat Recovery (MVHR)

AIRMASTER®



Energy Monitoring and Management

EnergiRaven




Electric Boilers

VÄRMEBARONEN



Hydronic Solutions

FloCon Watchman



Pressure Independent TRVs

Danfoss




Biogas CHP

EC POWER




EnergiRaven

White Papers



NI 80% Oil



40+ White Papers



80% .gov download



East of England


Heat Transmission Highway



Making Schools Heat Network Ready




Energy Efficient Schools



1st Generation Heat Pumps

- Designed for cooling
- Small delta T
- Poor COP in heating systems

SAV_s | DELTA





Minimising Return Temperatures

- Maximising heat pump COP

Minimising Flow Rates

- Decreasing pipe sizes
- Decreasing pump sizes
- Decreasing pumping energy

Maximising Thermal Storage Capacity

2nd Generation 60/30 Heat Pumps

- Designed for **heating**
- **High** delta T
- **High** COP for heating system

SAV_s | DELTA



Natural Refrigerants

R744 – CO₂

- Needs large delta T at heat sink.
- DHW applications 10/60.
- High pressures = cost and complexity.


R600a – Isobutane

- High source and sink temperatures.
- Second stage of cascade.
- Water to water – high source temp.
- Flammability class A3.


R290 – Propane

- ASHP in colder climates.
- Compatible with heat network flow/return temps.
- Flammability class A3.


SAV₉ | DELTA



Hybrid Heat Pump and Electric Boiler



Thermal Storage



Thermal Storage

- Optimising heat pump production
- Lean heat production
- DHW store



Instantaneous DHW Performance

SAV | DELTA



Point of use electric DHW

COP = 1




Point of use mechanical DHW


COP > 3.5



70/30 Energy Centre | SCOP 3.5




Energy Efficient Schools



Passivhaus Heat Recovery | 75+%

SAV_o | DELTA




Supply Air Temperatures



| Outdoor Temperature (°C) | Room Temperature (°C) | 40% Heat Recovery Efficiency (°C) | 84% Heat Recovery Efficiency (°C) |
|--------------------------|-----------------------|-----------------------------------|-----------------------------------|
| 0 | 21 | 8.4 | 17.6 |
| 5 | 21 | 11.4 | 18.4 |
| 10 | 21 | 14.4 | 19.2 |
| 15 | 21 | 17.4 | 20.0 |

Natural Ventilation


60 kWh/m²/year



40% Heat Recovery Efficiency


SAV_s | DELTA

33 kWh/m²/year




84% Heat Recovery Efficiency

10 kWh/m²/year




Heat Pump CAPEX & MVHR

- Increasing from 40% to 84% heat recovery efficiency reduces peak heat demand in classrooms by 47%



Energy Efficient School Design

SAV_® | DELTA



Assessment Input

- Geographical location
- Heat recovery efficiency
- Heating profile
- DHW profile
- Peak heat demand



DELTA Plant Assessment

Heat pump only

- Highest CAPEX
- Lowest OPEX
- SCOP 3.33

Heat Pump Sizing Assessment

Project Ref SAV/HP/116518/IS/22 Jan 2025
 Project Name Blocks C, D & E Combined
 Proposal 3no SAV DELTA-HP4 Heat Pump sized to peak
 Assessor TP



Headlines

Source of emission factors:
 SAP 10.2


Weather Data Used (CIBSE TRY):
 1 London - South East

Project Estimated
 Heat Demand
 1,463,748 kWh


Site Temperatures
 Flow: 60°C
 Return: 34°C

Heat Pump
 Constant Outlet Temperature
 60°C


Project Specific COP/SCOP
 SCOP = 3.33




Heat Pump Share
 100.0%




Carbon Footprint (kg/CO₂)
 -82%



Comparison with Notional Building
 Primary Energy kWh
 -65%



Operating Cost (£)
 -1%



* Notional building with gas boiler

Hybrid Plant Assessment

Hybrid – Heat pump + E-Boiler

- **62%** lower CAPEX
- Increased OPEX
- **SPF 3.00** incl. boiler

Heat Pump Sizing Assessment

Project Ref: SAV/HP/116518/IS/22 Jan 2025
 Project Name: - Blocks C, D & E Combined
 Proposal: 1no SAV DELTA-HP4 Heat Pump + Electric Boiler
 Assessor: TP



Headlines



Source of emission factors:
SAP 10.2

Weather Data Used (CIBSE TRY):
1 London - South East


Project Estimated
Heat Demand
1,463,748 kWh

Site Temperatures
Flow: 60°C
Return: 34°C


Heat Pump
Constant Outlet Temperature
60°C




Carbon Footprint (kg/CO₂)
-80%



Comparison with Notional Building
Primary Energy kWh
-61%



Operating Cost (£)
+9%



* Notional building with gas boiler

Energy Efficient School Design

SAV | DELTA

